

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 2020-0226:107

Page 1 of 1

CATEGORY: Acoustical Materials

LISTEE: USG Interiors, 1000 Crocker Road, Westlake OH 44145
Contact: *Phil Shaeffer (312) 606-3738 Fax (312) 214-6629

DESIGN: Model AURATONE GR. Refer to listee's data sheet for detailed product description and operational considerations.

RATING:	Flame Spread	15-25
	Fuel Contributed	5
	Smoke Density	0-15

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, hazard classification and UL label.

APPROVAL: Listed as an interior finish material having a Class I flame spread rating. Authority having jurisdiction should be consulted prior to installation.

NOTE: Formerly 2020-0106:052

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager